CBCS SCHEME

USN												17ME43
-----	--	--	--	--	--	--	--	--	--	--	--	--------

Fourth Semester B.E. Degree Examination, June/July 2023 Applied Thermodynamics

Time: 3 hrs. Max. Marks: 100

Note: 1. Answer any FIVE full questions, choosing ONE full question from each module.

2. Use of steam table and thermodynamic data handbook is permitted.

Module-1

- a. What is an air standard efficiency? Derive an expression for air standard efficiency of an Otto cycle. (07 Marks)
 - b. In an air standard diesel cycle, the compression ratio is 16, and at the beginning of isentropic compression, the temperature is 15°C and the pressure is 0.1 MPa. Heat is added until the temperature at the end of the constant pressure process is 1480°C. Calculate:
 - (i) Cut-off ratio
 - (ii) The heat supplied per kg of air
 - (iii) The cycle efficiency
 - (iv) M.E.P.

(13 Marks)

OR

- 2 a. With the help of line diagram and T-S diagram, explain inter cooling and reheating in gas turbine cycle. (10 Marks)
 - b. Air enters the compressor of an ideal air standard Brayton cycle at 100 kPa, 300 K with a volumetric flow rate of 6 m³/s. The compressor pressure ratio is 10. The turbine inlet temperature is 1500 K. Determine:
 - (i) The thermal efficiency
 - (ii) The power output.

(10 Marks)

Module-2

- a. Discuss with help of T-S diagram the effect of boiler pressure condenser pressure on the performance of a Rankine cycle with P-V and T-S diagram. (08 Marks)
 - b. Steam at 20 bar, 360°C is expanded in a steam turbine to 0.08 bar. It then enters a condenser, where it is condensed to saturated liquid water. The pump feeds back the water into the boiler.
 - (i) Assuming ideal process, find per kg of steam the net work and the cycle efficiency.
 - (ii) If the turbine and the pump have each 80% efficiency, find the percentage reduction in the net work and cycle efficiency. (12 Marks)

OR

- 4 a. With the help of schematic diagram and T-S diagram, explain reheat Rankine cycle and derive an expression for its thermal efficiency. (08 Marks)
 - b. A 40 MW steam power plant working on Rankine cycle operates between boiler pressure of 4 MPa and condenser pressure of 10 kPa. The steam leaves the boiler and enters the steam turbine at 400°C, the isentropic efficiency of the steam turbine is 85%. Determine:
 - (i) The cycle efficiency
 - (ii) The quality of exhaust steam from the turbine
 - (iii) The steam flow rate in kg per hour, consider pump work.

(12 Marks)

Module-3

- 5 a. Explain the following terms with reference to a combustion process:
 - (i) Stoichiometric air
 - (ii) Enthalpy of formation
 - (iii) Enthalpy of combustion
 - (iv) Combustion efficiency

(08 Marks)

- b. The product of combustion of an unknown hydrocarbon C_XH_Y have the following composition as measured by an Orsat apparatus $CO_2 = 8\%$, $O_2 = 8.8\%$, CO = 0.9%, $N_2 = 82.3\%$. Determine:
 - (i) Composition of the fuel
 - (ii) Air/fuel ratio
 - (iii) Percentage of excess air used

(12 Marks)

OR

- 6 a. Explain the phenomenon of knocking in SI engine. What are the different factors which influence the knocking? (10 Marks)
 - b. The following particulars refers to a 2-stroke diesel engine:

 Bore = 10 cm, Stroke = 15 cm, Piston speed = 300 m/min, torque developed = 58 Nm, mechanical efficiency = 80%, indicated thermal efficiency = 40%, calorific value of fuel = 44 MJ/kg. Determine:
 - (i) Indicated power
 - (ii) Indicated mean effective pressure
 - (iii) Fuel consumption per kWh on brake power output.

(10 Marks)

Module-4

- 7 a. With neat sketch, explain the working of a vapour absorption refrigeration system. (08 Marks)
 - b. A vapour compression refrigerator of 10 tonnes capacity using Freon-12 as the refrigerant has an evaporator temperature of -10° C and a condenser temperature of 30° C. Assuming simple saturation cycle, determine: (i) Mass flow rate of refrigerant in kg/min (ii) Power input (iii) COP. Take $C_{PV} = 0.72 \text{ kJ/kgK}$. (12 Marks)

OR

- 8 a. Define the following:
 - (i) Dry bulb temperature
 - (ii) Dew point temperature
 - (iii) Relative humidity
 - (iv) Degree of saturation

(08 Marks)

- b. It is required to design an air conditioning plant for a office room with the following conditions: outdoor conditions 14°C DBT and 10°C WBT; required conditions 20°C DBT and 60% R.H.; amount of air circulation 0.30 m³/min/person. Seating capacity of office 60. The required condition is achieved first by heating and then by adiabatic humidifying. Determine the following:
 - (i) Heating capacity of the coil in KW and the surface temperature required if the bypass factor of coil is 0.4.
 - (ii) The capacity of the humidifier.

(12 Marks)

Module-5

- Define the following with respect to compressor:
 - Isothermal efficiency
 - Adiabatic efficiency (ii)
 - (iii) Mechanical efficiency

(iv) Volumetric efficiency

(08 Marks)

- b. A single acting reciprocating compressor with cylinder of 15 cm diameter and 18 cm stroke has a clearance volume of 4% of swept volume. It takes in air at 1 bar 25°C and delivers at 8 bar while running at 1200 rpm. The actual power input is 18 KW. Estimate:
 - The power required to drive the unit
 - The isothermal efficiency
 - (iii) The mechanical efficiency when the mass flow rate is 4 kg/min.

(12 Marks)

OR

Discuss the different shapes of nozzle.

(04 Marks)

- Discuss the following:
 - Effect of friction in nozzle flow
 - (06 Marks) (ii) Supersaturated flow through nozzle
- What is critical pressure ratio? Derive an expression for pressure ratio which gives (10 Marks) maximum discharge through the nozzle.